

## Esposito & Associates

---

**From:** Roy, Aparna (DEC) <aparna.roy@dec.ny.gov>  
**Sent:** Thursday, August 17, 2017 11:13 AM  
**To:** eanda@espositoandassociates.net  
**Subject:** RE: Apple Ridge Town of New Windsor Effluent Limits

Hello Steve, Our Water Quality Engineer provided the following preliminary effluent limits. Thanks-Aparna

Either location is an ISEL to a class C, pH 7.5 so the limits would be:

BOD	5 mg/l
TSS	10 mg/l
DO	7.0 mg/l daily min
SS	0.1 ml/l
pH	6.5 – 8.6
NH3 summer/winter	1.5/2.2 mg/l (as NH3)