

**FIRE INSPECTOR'S
INTER-OFFICE CORRESPONDENCE**

TO: Genaro Argenio, Planning Board Chairman

FROM: Thomas Lucchesi, Asst. Fire Inspector

**SUBJECT: PB-08-10
Louie's Driving School
SBL: 42-1-15**

DATE: October 15, 2008

Fire Prevention Reference Number: FPS-08-044

A review of the above referenced plan has been conducted and is disapproved for the following reason:

- 1) 30 foot Fire Dept. Access requires apparatus to jump Concrete curb.**