

INTER-OFFICE CORRESPONDENCE

TO: Town Planning Board
FROM: Town Fire Inspector
SUBJECT: Stewart Terrace Subdivision
DATE: 22 June 2002


Planning Board Reference Number: PB-02-16
Dated: 19 June 2002
Fire Prevention Reference Number: FPS-02-042

A review of the above referenced subdivision plan was conducted on 21 June 2002, with the following being noted:

1. Please identify what A, B, C and D represent.
2. It appears that at the end of Stillman Avenue there will be curbs installed. Remove curbs so that Stillman continues to be a through street
3. Identify hydrant locations.
4. Provide fire flow calculations to ensure there is adequate fire flow for multiple dwelling.

The subdivision plan at this time is not acceptable..

Plans Dated: 24 May 2002


Robert F. Rodgers